

Increased steam temperature with Steamboost superheater in grate fired boilers

- linking deposit formation and high temperature corrosion (KME709)



Thomas Norman Lars Mikkelsen



Loli Paz Johan Eklund Torbjörn Jonsson




Bo Jönsson Susanne Selin




Johan Hernblom Mats Lundberg



Research strategy and correlation to KME goals



Alumina forming alloys - FeCrAl



Waste fired boilers - New position of superheaters

- Higher steam parameters & high electrical efficiency
- Development of novel solutions where steam is superheated in the furnace
- Develop improved material solutions including alumina formers




Grate fired boiler

- What's the idea behind Steamboost?



- Different processes over the grid.
- CFD calculations indicates a position over the grid with less corrosive species.
- New position of superheaters!





Research strategy - Steamboost

Investigate the Steamboost position is a commercial plant – AffaldPlus

CFD modeling

Fixed installations


Deposit tests

Corrosion tests






Deposit test





Probe exposures




- Deposit test 2 hours exposures High alloyed Stainless steel samples Temperatures 525 and 700°C
- 29 exposures

Deposit investigation – impact of boiler settings









- Large number of settings tested deposits formed at 525° C and 700° C
- Small/no difference between exposure temperatures
- All aspects of deposit formation possible to influence



Corrosion test - probe




Probe exposures



- Corrosion test 24 and 1000 hours exposures
- Stainless steels, High alloyed Stainless steel and FeCrAl samples
- Temperatures 525 and 700 °C


Corrosion investigation – probe exposures




- Generally high corrosion rates, both at 525° C and 700° C
 - Higher levels of Cl detected in corrosion producs after short exposures (24h)
 - No clear trends: alloying element corrosion resistance
- FeCrAl Model alloy (indications of protective alumina)



Corrosion test – fixed installed material







- Corrosion test 8000h and about 6000 hours exposures
- Stainless steels, High alloyed Stainless steel and FeCrAl samples
- Temperatures 340-525 °C

TUBE 1 INLET


Material loss - Steamboost

TUBE 3 OUTLET





Tested during the deposit-setting tests



TUBE 3 INLET

TUBE 1 OUTLET

- Low corrosion rates observed at the tubes with temperatures 340-470C
- Higher corrosion rates at 525C –
 very high for some samples
- Promising corrosion rate for some samples 347H (one of the exposures)




Corrosion attack - microstructure


347 stainless steel


24h 525C

1000h 525C

8000h Steamboost








Air cooled probe



Steamboost - summary of the results

- It is possible to influence all aspects of deposit formation at the Steamboost position by changing the settings of the boiler
- Probe tests showed high corrosion rates compared to fixed installed samples. However, similar type of corrosion attack as the fixed installation. Higher Cl content on the probe samples (short exposures)
- The FeCrAl model alloy sample show promising corrosion behavior in this environment
- Fixed installed samples exposed during deposit tests. Promising results on some material/samples high corrosion rates on some samples. More work needed

Research strategy and correlation to KME goals



Combined heat and power plant
AffaldPlus, Denmark


Alumina forming alloys - FeCrAl

Waste fired boilers - New position of superheaters

- Higher steam parameters & high electrical efficiency
- Development of novel solutions where steam is superheated in the furnace
- Develop improved material solutions including alumina formers




Research strategy – a two pronged approach



- Preoxidation of FeCrAl alloys
- Optimizing FeCrAl alloy composition



Pre-oxidation of FeCrAl alloys



- Pre-oxidized FeCrAl samples tested in the lab (HTC)
- Al₂O₃ formed at higher temperatures – resists accelerated corrosion by **KC**1

Protective alumina – KCl evaporation - no corrosion

Boiler exposure – un-cooled FeCrAl tube



Pre-oxidized FeCrAl tube exposed at the steamboost position at 900 C


- Pre-oxidized FeCrAl samples tested in the lab (HTC)
- Al₂O₃ formed at higher temperatures – resists accelerated corrosion by KCl








Boiler exposure – un-cooled FeCrAl tube


Protective alumina!













Temperature ≈ 900°C Time ≈ 4500 h


Boiler exposure – un-cooled FeCrAl tube


Lost protective alumina – fast corrosion - failure


















Temperature = 900°C Time = 12000 h



Research strategy – a two pronged approach



- Preoxidation of FeCrAl alloys
- Optimizing FeCrAl alloy composition



FeCrAl alloys are potential materials for biomass and waste fired environments



Develop new FeCrAl alloys for biomass and waste fired environments

Can the same trends be observed in the real applications


Existing FeCrAl alloys are optimized for higher temperatures





In close collaboration with Kanthal


Two trends observed:

Decreased amount of corrosion upon addition of Cr and Si














Alloys for field exposures (600° C) Part of KME 709

Probe with 8 sample locations:





| ref | 1 | 2 | 3 | 4 | 5 |
|-----------|----------|--------|--------|--------|--------|
| Alloy 625 | 532 | 10 3 2 | 15 3 2 | 20 3 2 | 10 3 0 |
| | Cr Al Si | | | | |





Alloy 2 (10Cr-3Al-2Si)

Alloy 3 (15Cr-3Al-2Si)

Before









Before exposure After exposure


Alloy 4 (20Cr-3Al-2Si)


Alloy 5 (10Cr-3Al-0Si)

















Alloy 1 (5Cr-3Al-2Si)




Alloy 2 (10Cr-3Al-2Si)




Alloy 3 (15Cr-3Al-2Si)




Alloy 4 (20Cr-3Al-2Si)





Alloy 5 (10Cr-3Al-0Si)




Material loss







Comparison with state of the art materials in these environments




Inconel 625


Summary - FeCrAl

- Similar trends observed for field and lab exposures
- Pre-oxidizing FeCrAl alloys prior to exposure results in a protective alumina layer
 - Decreased corrosion attack
 - Alumina fails during cycling and results in severe corrosion attack
- Addition of Cr results in a better corrosion resistance but makes the material more brittle
- Large difference in corrosion attack upon addition of Si
 - Decrease in material loss
- Some of the FeCrAl alloys show comparable corrosion resistance as state of the art materials in this environment

Summary and correlation to KME goals



Alumina forming alloys - FeCrAl



Waste fired boilers - New position of superheaters

- > Higher steam parameters & high electrical efficiency
- Development of novel solutions where steam is superheated in the furnace
- Develop improved material solutions including alumina formers